



COOPER'S CAMP MUNICIPALITY
CONSTRUCTION SITE FIRST VISIT REPORT

First Visit : PROP-01791 - Coopers Colony High School

Location Details

| Name of the Location | Latitude & Longitude | Ward | Area | Area Unit |
|----------------------------|--------------------------|------|------|-----------|
| Coopers Colony High School | 22.5797224 88.4136035 | 5 | 50 | Sq/Meter |





Project Details

| Proposed Project Type | Toilet Seat (Male) | Toilet Seat (Female) | Urinal Seat (Male) | Urinal Seat (Female) |
|----------------------------|--------------------|----------------------|--------------------|----------------------|
| Institutional Toilet Block | 2 | 2 | 3 | 2 |

Land Details

| Classification | Plot No. | Jl No. | Dag No. | Khatian No. | Mouza | Possession Details (Owned by) |
|----------------|----------|--------|---------|-------------|------------|-------------------------------|
| Bastu | NA | 158 | NA | NA | Magurkhali | |

Foundation upto Tie beam with reinforcement details

| | | | | | | |
|---------------------------------------|--|--------------|------------|------------|--------|---------|
| Visit Date | 15/05/2026 | | | | | |
| Earth Cutting (1200 x 1200 x 1000) | Column Nos. | Length (M) | Breath (M) | Height (M) | Status | Remarks |
| | 10 | 1200 | 1200 | 1000 | OK | OK |
| Earth Cutting Image |  | | | | | |
| Re-inforcement | | | | | | |
| Footing (10 mm dia 10 nos both) | Rod Nos. | Diameter (M) | Status | Remarks | | |
| | 10 | 10 | OK | OK | | |
| Footing Image |  | | | | | |
| Column (12 mm dia 6 nos) | Rod Nos. | Diameter (M) | Length (M) | Height (M) | Status | Remarks |
| | 6 | 12 | 250 | 250 | OK | OK |
| Column Image |  | | | | | |
| Tie beam (12 mm dia 4 nos) | Rod Nos. | Diameter (M) | Length (M) | Breath (M) | Status | Remarks |
| | 4 | 12 | 250 | 250 | OK | OK |
| Tie beam Image |  | | | | | |
| Binder for Column 8 mm dia 175 mm C/C | Status | | | | | Remarks |
| | OK | | | | | OK |
| Binder for Tie 8 mm dia 175 mm C/C | Status | | | | | Remarks |
| | OK | | | | | OK |
| Overall Remarks | Ok | | | | | |

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



QR Code Board Image



Signatures & Approval

Seal with signature of ULB Engineer
Name : _____
Contact no. : _____

Signature of Engineer
HILLI INSPIRATION
Name : _____
Contact no. : _____

Signature of Co-Ordinator
HILLI INSPIRATION