



ENGLISH BAZAR MUNICIPALITY  
CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-00720 - B.S road (old Pump House)

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
B.S road (old Pump House)	22.579711 88.4135353	11	32.32	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	2	2	3	2

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Bastu	1105	65	1105	527, 6386	Purapara	

At the time of Roof Casting - Visit Details

Visit Date

09/12/2025

Roof Beam Top Support  
(16 mm dia, 4 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Top Support Image



Roof Beam Bottom Support  
(16 mm dia, 2 nos.)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support  
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support  
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters  
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
---------------	------------	--------	---------

ails Parameters Image



Binder for Roof Beam Support (250mm X 250mm)

Status  
OK

Remarks  
OK

Binder for Roof Beam Mid Span Support

Status  
OK

Remarks  
OK

Binder for Roof 8mm dia 125mm C/C

Status  
OK

Remarks  
OK

Overall Remarks

Ok

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

**A. E. (C)**  
**English Bazar Municipality**  
**MALDA**  
 Seal with signature of the Engineer  
 Name : \_\_\_\_\_  
 Contact no. : \_\_\_\_\_

**Co-ordinator**  
**Hijli INSPIRATION**  
 Page 3 of 3

**Checked & Verified**  
  
**Engineer (Civil)**  
**Hijli INSPIRATION**

Signature of Engineer  
 HILLI INSPIRATION  
 Name : \_\_\_\_\_  
 Contact no. : \_\_\_\_\_

