



JALPAIGURI MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-01462 - Dinbazar Marowari Patty

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
Dinbazar Marowari Patty	26.5294889 88.7239345	5	Dinbazar Marowari Patty	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	4	3	5	5

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	399	7	21	1086	kharia	

Handwritten signature:
Ramon Das
Chief Engineer
High Irrigation



Binder for Roof Beam Support (250mm X 250mm)

Status	Remarks
OK	OK

Binder for Roof Beam Mid Span Support

Status	Remarks
OK	OK

Binder for Roof 8mm dia 125mm C/C

Status	Remarks
OK	OK

Overall Remarks

Overall construction satisfied. Recommended for finishing work.

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Sanku
 JUNIOR ENGINEER
 JALPAIGURI MUNICIPALITY

Page 3 of 3
Schettacharya
 Co-Ordinator
 Hijli Inspiration

Tanma Sen
 Civil Engineer
 Hijli Inspiration

At the time of Roof Casting - Visit Details

Visit Date

18/05/2026

Roof Beam Top Support
(16 mm dia, 4 nos.)

Rod Nos.

Diameter (mm)

Status

Remarks

4

16

OK

OK

Roof Beam Top Support Image



Roof Beam Bottom Support
(16 mm dia, 2 nos.)

Rod Nos.

Diameter (mm)

Status

Remarks

2

16

OK

OK

Roof Beam Bottom Support Image



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.

Diameter (mm)

Status

Remarks

2

16

OK

OK

Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.

Diameter (mm)

Status

Remarks

4

16

OK

OK

Roof Beam Mid Span Bottom Support Image

