

SAINTHIA MUNICIPALITY

CONSTRUCTION SITE SECOND VISIT REPORT

Second Visit : PROP-01654 - NANDIKESWARI TEMPLE

Location Details

Name of the Location	Latitude & Longitude	Ward	Area	Area Unit
NANDIKESWARI TEMPLE	22.5797287 88.4135515	5	25	Sq/Meter

Project Details

Proposed Project Type	Toilet Seat (Male)	Toilet Seat (Female)	Urinal Seat (Male)	Urinal Seat (Female)
PT (Public Toilet Project)	1	1	2	1

Land Details

Classification	Plot No.	Jl No.	Dag No.	Khatian No.	Mouza	Possession Details (Owned by)
Other	4177	95	NA	5359	SAINTHIA	

Construction Site Second Visit Report

At the time of Roof Casting - Visit Details

Visit Date 19/05/2026

Roof Beam Top Support (16 mm dia, 4 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	4	16	MISMATCH	Only one top extra bar

Roof Beam Top Support Image



Roof Beam Bottom Support (16 mm dia, 2 nos.)	Rod Nos.	Diameter (mm)	Status	Remarks
	2	16	OK	OK



Roof Beam Mid Span Top Support
(16 mm dia 2 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
2	16	OK	OK

Roof Beam Mid Span Top Support Image



Roof Beam Mid Span Bottom Support
(16 mm dia 4 nos)

Rod Nos.	Diameter (mm)	Status	Remarks
4	16	OK	OK

Roof Beam Mid Span Bottom Support Image



Roof Details Parameters
(8 mm dia 125 nos)

Diameter (mm)	Depth (mm)	Status	Remarks
8	125	OK	OK

Roof Details Parameters Image



Beam Support (250mm X 250mm)

Status
OK

Remarks
OK

For Roof Beam Mid Span Support

Status
OK

Remarks
OK

Cylinder for Roof 8mm dia 125mm C/C

Status
OK

Remarks
OK

Overall Remarks


No Mid Beam in ULB model

Overall Work Status - Images

Photo 1 - Angle 1



Photo 2 - Angle 2



Signatures & Approval

Debarpan @itha
CLTC

Seal with signature of ULB Engineer

Name: _____

Contact no.: _____

Checked & Verified

Shrestha

Engineer

HILL INSPIRATION

Signature of Engineer

HILL INSPIRATION

Name: *SUPREMO KHOSH*

Contact no.: *8622075848*

[Signature]
Co-ordinator
HILL INSPIRATION

Signature of Co-Ordinator
HILL INSPIRATION